



SCHEDULE "40" CONDUIT

QUEEN CITY PLASTICS Heavy Wall Schedule 40 conduit is produced from Underwriters Laboratories 90° C approved, QUEEN CITY PLASTICS 8121 rigid PVC (Polyvinyl Chloride) compound. The inherent properties of this PVC compound render the product ideal for above and below ground utilization as described in Article 347 of the National Electrical Code (NEC).

QUEEN CITY PLASTICS conduit is manufactured to and complies with the following specifications and should be installed in accordance with Article 347 of the National Electrical Code (NEC):

Underwriters Laboratories, Inc. (UL)
National Electrical Manufacturers Association (NEMA)
Federal Specification

UL-651
TC-2
WC-1094 A

**Rigid Nonmetallic Conduit
Above Ground and Underground
(Schedule 40)**



Sunlight Resistant

NOM SIZE	CATALOG NUMBER	O.D.	MIN WALL	WT. 100' BELL END	STD. BUNDLE	STD. PALLET
1/2"	1100531	.840	.109	17	100'	6,000'
3/4"	1100831	1.050	.113	23	100'	4,400'
1"	1101031	1.315	.133	34	100'	3,600'
1-1/4"	1101331	1.660	.140	46	50'	3,300'
1-1/2"	1101531	1.900	.145	55	50'	2,250'
2"	1102031	2.375	.154	76	10'	1,400'
2-1/2"	1102531	2.875	.203	120	10'	930'
3"	1103031	3.500	.216	157	10'	880'
3-1/2"	1103531	4.000	.226	189	10'	630'
4"	1104031	4.500	.237	222	10'	570'
5"	1105031	5.563	.258	299	10'	380'
6"	1106031	6.625	.280	390	10'	260'