



QUEEN CITY PLASTICS, INC.

PVC CONDUIT & FITTINGS

Charlotte, NC 28241
29715


Fort Mill, SC

Created by: Alan Romb, Quality Control Manager

Schedule EB TC-6 Conduit Belled End – 20' Lengths

Part Number	Trade Size	Feet per Skid	Skid Wt.	Walls Min. "T"	Nominal "OD"	Bell Entrance Min. "E"	Bell Length Min. "D"	Min. Length (L)
1362032	2"	2800'	958	.077	2.375	2.387	1.750	240"
1373032	3"	1760'	988	.085	3.500	3.515	2.875	240"
1373532	3-1/2"	1260'	932	.098	4.000	4.016	3.125	240"
1374032	4"	1140'	1,027	.106	4.500	4.517	3.375	240"
1375032	5"	760'	991	.124	5.565	5.583	4.000	240"
1376032	6"	520'	945	.145	6.625	6.646	5.000	240"

Note: Only 20' Length is available



ENCASED BURIAL
Meets specifications of UL651 and NEMA TC3
Rated for 90° C Cables
Sunlight
Resistant